

Current Benchmark Evaluation Efforts to Support Integral Nuclear Data

**Mini-CSEWG-2015
7 May 2015**

John D. Bess

Idaho National Laboratory (INL)


www.inl.gov



International Handbook of Evaluated Reactor Physics Benchmark Experiments

March 2015 Edition

- 20 Contributing Countries
- Data from 143 Experimental Series performed at 50 Reactor Facilities
- Data from 139 are published as approved benchmarks
- Data from 4 are published only in DRAFT form




<http://irpheap.inl.gov/>

<http://www.oecd-nea.org/science/wprs/irphe/>

IPEN/MB-01 Heavy Metal Reflectors

Carbon Steel
Stainless Steel
Nickel

Moderation
vs.
Scattering





Drawing not to scale
 Dimensions in cm

- Fuel rod
- Withdrawn safety rod
- Control rod BC1
- Control rod BC2

13-WHT03-09

Transition point
in MCNP not
“perfect”

MINERVE BUC Measurements (DRAFT)




C/E-1 < 10%

^{147}Sm , ^{149}Sm , ^{152}Sm , $^{\text{nat}}\text{Sm}$
 ^{143}Nd , ^{145}Nd , $^{\text{nat}}\text{Nd}$
 ^{153}Eu , ^{155}Gd , ^{103}Rh
 ^{95}Mo , ^{99}Tc , ^{133}Cs

Potassium Fast-Spectrum Validation at ORCEF

C/E-1 ~ -70%






14-WHT01-114


Analysis Code	Neutron Cross Section Library	Calculated			Benchmark Experiment			$\frac{C - E}{E} \%$
		$\rho(\epsilon)$	\pm	σ	$\rho(\epsilon)$	\pm	σ	
MCNP6	ENDF/B-VII.1	3.8	\pm	0.4	11.4	\pm	1.2	-67 \pm 5
	ENDF/B-VII.0	3.1	\pm	0.4				-73 \pm 5
	JEFF-3.1	2.3	\pm	0.4				-80 \pm 4
	JENDL-3.3	2.4	\pm	0.4				-79 \pm 4

Additional ORSphere Measurements

Relative Neutron Importance and Fission Density Distributions




SCCA Reactivity Effects Measurements




14-WHT01-85-

SS347, W, Nb, PE, C rodlets
C/E-1 ~ 30, -30, 100, -10, 2%
Benchmark Uncertainty
~30%

Sodium Streaming Effects in ZPPR-12: Mockup of Clinch River Breeder Reactor



Normal ZPPR-12 Fuel Cell



Rearranged ZPPR-12 Fuel Cell

■ ZPPR Pu
■ Na
 Fe₂O₃


14-WHT01-79

C/E-1...
Results range from
+125 to -940%
One skeptical result
-2400%

International Handbook of Evaluated Criticality Safety Benchmark Experiments

September 2014 Edition

- 20 Contributing Countries
- ~67,000 Pages
- 561 Evaluations
 - 4,839 Critical, Near-Critical, or Subcritical Configurations
 - 24 Criticality Alarm Placement/Shielding Configurations
 - 207 Configurations with Fundamental Physics Measurements
 - 829 Unacceptable Experiment Configurations



<http://icsbep.inl.gov/>


<https://www.oecd-nea.org/science/wpncs/icsbep/>

ICSBEP Meeting Next Week (11-12 May 2015)


- **SCCA-003**
 - Potassium Worth Measurement
- **IPEN/MB-01 Reactor**
 - Criticality with Mo Rods
- **SNL 7uPCX**
 - U(6.9%)O₂ Rods in 19 Critical Lattice Configurations
- **SILENE Bare Pulse**
 - Neutron Activation and TLD Responses
- **U(37%)O₂F₂ Sphere**
 - IEU-SOL-THERM
- **Oralloy Configurations**
 - Bare Metal Annuli
 - Complex Metal Annuli
 - Bare Metal Annuli with Graphite Cores

Nuclear Data Points of Interest

- TRIGA Reactors
 - UZrH or UErZrH Fuel
- Fast-Spectra Graphite
 - HEU-MET-FAST-071
- Thermal-Spectra Graphite
 - HTTR
 - HTR-PROTEUS



Neutron Radiography (NRAD) Reactor



Small Uncertainties

Summary of Experimental Uncertainties*

Parameter\Number of fuel elements	56	60	62	64
Mass of ^{235}U in fuel	18	18	18	18
^{234}U content in fuel	29	31	27	30
^{236}U content in fuel	43	46	49	48
Hydrogen-to-zirconium ratio in fuel	19	18	19	18
Erbium content in fuel	50	49	49	50
Manganese content in steel clad	71	68	65	70
Nickel content in steel clad	17	14	20	12
Impurities in steel clad	36	35	36	42
Impurities in boron carbide absorber	19	10	10	10
Graphite reflector block density	14	12	14	11
Graphite reflector block dimensions	14	14	19	15
Water saturation of graphite blocks	19	Negligible	Negligible	17
Assembly pitch in grid plate	16	18	15	17
Diameter of assembly holes in grid	13	14	12	13
Impurities in tank water	26	10	10	10
Placement of beam lines	11	14	12	Negligible
Total experimental uncertainties	122 (0.163 \$)	116 (0.155 \$)	116 (0.155 \$)	120 (0.160 \$)

*In pcm.

Neutron Radiography (NRAD) Reactor


- Calculated $k_{\text{eff}} \sim 1.4\%$ (1.75 \$, 9σ) greater than benchmark k_{eff}
- Similar problems with other HEU and LEU TRIGA reactors including Slovenia TRIGA reactor benchmark
- Slovenian's believe due to ^{91}Zr and thermal scattering data for ZrH
 - “Higher elastic scattering resonance integral increases thermal neutron flux by improving neutron thermalization”
- Minimal to no impact on control rod worth calculations

Comparison of Benchmark Experiment (k_E) and Calculated (k_C) Eigenvalues Using MCNP5 with ENDF/B-VII.0 Nuclear Data


Number of Fuel Elements	Calculated	Benchmark	$\frac{k_C - k_E}{k_E} (\%)$
	$k_C \pm \sigma$	$k_E \pm \sigma$	
56	1.01412 ± 0.00007	1.0012 ± 0.0015	1.29
60	1.01413 ± 0.00007	1.0012 ± 0.0015	1.29
62	1.01459 ± 0.00007	1.0011 ± 0.0015	1.35
64	1.01479 ± 0.00007	1.0012 ± 0.0015	1.36

Thin Graphite Reflected (1" and 2") (HEU-MET-FAST-071) revised

Experiment 6




Region (nominal)	Height (cm)	Average Gap (cm)
Fuel height, 22.86 cm ID, 27.94 cm OD region	8.037322	0.00150368
Fuel height, 27.94 cm ID, 33.02 cm OD region	8.049260	0.00194818
Fuel height, 33.02 cm ID, 38.10 cm OD region	8.050022	0.00906780
Graphite stack, 43.18 cm OD, 38.10 cm ID	18.177256	0.02658618
Graphite stack, 48.26 cm OD, 43.18 cm ID	18.186854	0.04457710
Graphite core	7.957312	0.00660400




Bottom layer
Dimensions in cm Reference numbers (see Table 21) Part numbers (see Table 19)

Thick Variants
To Be Investigated



HMF-071




HMF-071



High Temperature Engineering Test Reactor (HTTR)



08-GA50017-116-1



08-GA50017-116-2



HTTR
 k_{eff} 's

Case Number	Nuclear Data Library	Benchmark Experiment Eigenvalue			Calculated Eigenvalue	$\frac{k_C - k_E}{k_E}$ (%)
		k_E	-1σ	$+1\sigma$	$k_C \pm 1\sigma$	
1	ENDF/B-VI.8	1.0048	-0.0103	+0.0100	1.0267 \pm 0.0001	2.17
	ENDF/B-VII.0				1.0276 \pm 0.0001	2.27
	ENDF/B-VII.1				1.0143 \pm 0.0001	0.94
	JEFF-3.1				1.0280 \pm 0.0001	2.31
	JENDL-3.3				1.0222 \pm 0.0001	1.73
2	ENDF/B-VI.8	1.0040	-0.0100	+0.0092	1.0289 \pm 0.0001	2.48
	ENDF/B-VII.0				1.0297 \pm 0.0001	2.55
	ENDF/B-VII.1				1.0173 \pm 0.0001	1.32
	JEFF-3.1				1.0301 \pm 0.0001	2.60
	JENDL-3.3				1.0241 \pm 0.0001	1.99
3	ENDF/B-VI.8	1.0035	-0.0078	+0.0084	1.0243 \pm 0.0001	2.07
	ENDF/B-VII.0				1.0249 \pm 0.0001	2.13
	ENDF/B-VII.1				1.0141 \pm 0.0001	1.06
	JEFF-3.1				1.0257 \pm 0.0001	2.21
	JENDL-3.3				1.0198 \pm 0.0001	1.62
4	ENDF/B-VI.8	1.0032	-0.0080	+0.0074	1.0284 \pm 0.0001	2.52
	ENDF/B-VII.0				1.0287 \pm 0.0001	2.54
	ENDF/B-VII.1				1.0191 \pm 0.0001	1.59
	JEFF-3.1				1.0298 \pm 0.0001	2.65
	JENDL-3.3				1.0239 \pm 0.0001	2.07
5	ENDF/B-VI.8	1.0029	-0.0068	+0.0075	1.0211 \pm 0.0001	1.82
	ENDF/B-VII.0				1.0218 \pm 0.0001	1.88
	ENDF/B-VII.1				1.0117 \pm 0.0001	0.87
	JEFF-3.1				1.0224 \pm 0.0001	1.94
	JENDL-3.3				1.0167 \pm 0.0001	1.37
6	ENDF/B-VI.8	1.0025	-0.0060	+0.0071	1.0222 \pm 0.0001	1.96
	ENDF/B-VII.0				1.0229 \pm 0.0001	2.03
	ENDF/B-VII.1				1.0141 \pm 0.0001	1.15
	JEFF-3.1				1.0236 \pm 0.0001	2.10
	JENDL-3.3				1.0178 \pm 0.0001	1.53
6sub	ENDF/B-VI.8	0.6876	-0.0104	+0.0104	0.7025 \pm 0.0001	2.17
	ENDF/B-VII.0				0.6999 \pm 0.0001	1.78
	ENDF/B-VII.1				0.7001 \pm 0.0001	1.82
	JEFF-3.1				0.7036 \pm 0.0001	2.33
	JENDL-3.3				0.6979 \pm 0.0001	1.50
7	ENDF/B-VII.0	1.0019	-0.0057	+0.0068	1.0195 \pm 0.0001	1.75
8	ENDF/B-VII.0	1.0024	-0.0057	+0.0067	1.0201 \pm 0.0001	1.77

*Calculations performed using MCNP5-1.51 except for ENDF/B-VII.1, which used MCNP6.1.

High Bias
but
Large EBC
Uncertainty

HTR-PROTEUS



● Plastic rods:	654
● Fuel pebbles:	184
● Moderator pebbles:	<u>177</u>
Total pebbles:	361

11-GA50002-72-7

HTR-PROTEUS Calculations


Core Number	Benchmark Eigenvalue	Calculated Eigenvalue	$\frac{k_C - k_B}{k_B}$
	$k_B \pm 1\sigma$	$k_C \pm 1\sigma$	(%)
1	1.0048 \pm 0.0030	1.0106 \pm 0.0001	0.58
1A	1.0034 \pm 0.0031	1.0095 \pm 0.0001	0.60
2	1.0029 \pm 0.0033	1.0104 \pm 0.0001	0.75
3	0.9999 \pm 0.0033	1.0089 \pm 0.0001	0.90
4	1.0039 \pm 0.0036	1.0174 \pm 0.0001	1.34
5	1.0024 \pm 0.0030	1.0071 \pm 0.0001	0.47
6	1.0014 \pm 0.0041	1.0065 \pm 0.0001	0.51
7	1.0017 \pm 0.0034	1.0086 \pm 0.0001	0.69
8	1.0030 \pm 0.0030	1.0081 \pm 0.0001	0.51
9	1.0029 \pm 0.0036	1.0058 \pm 0.0001	0.38
10	1.0020 \pm 0.0037	1.0067 \pm 0.0001	0.54

*Calculations were performed with MCNP5 and ENDF/B-VII.0.

Core Number	Benchmark Eigenvalue	Calculated Eigenvalue	$\frac{k_C - k_B}{k_B}$
	$k_B \pm 1\sigma$	$k_C \pm 1\sigma$	(%)
1	1.0048 \pm 0.0030	0.9989 \pm 0.0001	-0.58
1A	1.0034 \pm 0.0031	0.9970 \pm 0.0001	-0.64
2	1.0029 \pm 0.0033	0.9969 \pm 0.0001	-0.60
3	0.9999 \pm 0.0033	0.9978 \pm 0.0001	-0.21
4	1.0039 \pm 0.0036	1.0026 \pm 0.0001	-0.13
5	1.0024 \pm 0.0030	0.9931 \pm 0.0001	-0.93
6	1.0014 \pm 0.0041	0.9977 \pm 0.0001	-0.37
7	1.0017 \pm 0.0034	0.9984 \pm 0.0001	-0.33
8	1.0030 \pm 0.0030	0.9950 \pm 0.0001	-0.80
9	1.0029 \pm 0.0036	0.9910 \pm 0.0001	-1.19
10	1.0020 \pm 0.0037	0.9949 \pm 0.0001	-0.71



*Calculations were performed with MCNP6.1 and ENDF/B-VII.1.

Questions?





EXTRA SLIDES

IPEN/MB-01 Subcritical Configurations





LR(0) VVER-1000 Mockup




Currently k_{eff} ; to evaluate reaction-rate and power distributions

HTR-PROTEUS Cores 5-8 Rod Worth Measurements





RB Reactor RB39/1978 – External Neutron Converter





- 2% ENRICHED U METAL FA, LATTICE PITCH 11.31 cm
- 2% ENRICHED U METAL FA, LATTICE PITCH 8.0 cm
- NATURAL U METAL RODS, LATTICE PITCH 11.31 cm
- EMPTY POSITION IN LATTICE
- 80% ENRICHED URANIUM DIOXIDE SLUGS IN ENC

RB Reactor RB58/1982 – VINET: Experimental Fuel Channel





SSCR Spectral Measurements for Uranium-Thorium Rods in Heavy-Light Water Mixture




Thermal Disadvantage Factor: C/E-1 ~ 4%

ZPR-3/58: Pu-C Reflected by DU


ZPR-3/59: Pu-C Reflected by Pb



HTTR – Additional Benchmark Calculations



Axial Neutron Reaction-Rate in the Instrumentation Columns of the Fully-Loaded HTTR Core



HTR-PROTEUS Calculations

Calculations of HTR-PROTEUS Rod Worth Measurements with MCNP5 and ENDF/B-VII.0

Core Number	Measured Parameter	Method	Benchmark Worth	Calculated Worth	$\frac{\rho_C - \rho_B}{\rho_B}$ (%)
			$\rho_B \pm 1\sigma$	$\rho_C \pm 1\sigma$	
4	Control rod 1	SP	-0.40 ± 0.04	-0.35 ± 0.02	-13
	Control rod 2	SP	-0.38 ± 0.03	-0.34 ± 0.02	-11
	Control rod 3	SP	-0.37 ± 0.03	-0.35 ± 0.02	-5
	Control rod 4	SP	-0.39 ± 0.04	-0.37 ± 0.02	-5
	Control rod bank	SP	-1.54 ± 0.09	-1.44 ± 0.07	-6
9	Control rod 1	IK	-0.41 ± 0.02	-0.38 ± 0.02	-7
	Control rod 2	IK	-0.41 ± 0.02	-0.37 ± 0.02	-10
	Control rod 3	IK	-0.41 ± 0.02	-0.38 ± 0.02	-7
	Control rod 4	IK	-0.41 ± 0.02	-0.38 ± 0.02	-7
	Control rod bank	SP	-1.58 ± 0.09	-1.55 ± 0.08	-2
	Partial bank insertion	SP	-0.73 ± 0.04	-0.70 ± 0.04	-4
	Autorod	IK	-0.10 ± 0.01	-0.12 ± 0.02	20
	Safety/shutdown rod 5	IK	-3.74 ± 0.17	-3.78 ± 0.19	1
	Safety/shutdown rod 6	IK and PNS	-3.82 ± 0.10	-3.82 ± 0.19	<1
	Safety/shutdown rod 7	IK	-3.70 ± 0.30	-3.82 ± 0.19	3
	Safety/shutdown rod 8	IK	-3.60 ± 0.29	-3.70 ± 0.19	3
	Safety/shutdown rods 5+6	IK and PNS	-8.02 ± 0.20	-8.03 ± 0.40	<1
	Safety/shutdown rods 5+7	IK	-7.44 ± 0.60	-7.76 ± 0.39	4
	Safety/shutdown rods 5+8	IK	-7.40 ± 0.59	-7.69 ± 0.38	4
	Safety/shutdown rods 5+6+7	IK and PNS	-12.11 ± 0.28	-12.30 ± 0.61	2
	Safety/shutdown rods 5+6+7+8	IK and PNS	-16.52 ± 0.42	-16.98 ± 0.85	3
	10	Control rod 1	IK	-0.30 ± 0.02	-0.29 ± 0.02
Control rod 2		IK	-0.29 ± 0.02	-0.28 ± 0.02	-3
Control rod 3		IK	-0.29 ± 0.02	-0.25 ± 0.02	-14
Control rod 4		IK	-0.30 ± 0.02	-0.28 ± 0.02	-7
Control rod bank		SP	-1.15 ± 0.07	-1.11 ± 0.06	-3
Partial bank insertion		SP	-0.39 ± 0.02	-0.37 ± 0.02	-5
Autorod		IK	-0.073 ± 0.004	-0.08 ± 0.01	10
Safety/shutdown rod 5		IK	-2.82 ± 0.11	-2.73 ± 0.14	-3
Safety/shutdown rod 6		IK and PNS	-2.82 ± 0.09	-2.75 ± 0.14	-2
Safety/shutdown rod 7		IK	-2.80 ± 0.16	-2.73 ± 0.14	-2
Safety/shutdown rod 8		IK	-2.72 ± 0.15	-2.66 ± 0.13	-2
Safety/shutdown rods 5+6		IK and PNS	-5.95 ± 0.17	-5.70 ± 0.29	-4
Safety/shutdown rods 5+7		IK	-5.73 ± 0.32	-5.54 ± 0.28	-3
Safety/shutdown rods 5+8		IK	-5.75 ± 0.33	-5.49 ± 0.27	-5
Safety/shutdown rods 5+6+7		IK and PNS	-9.29 ± 0.21	-8.65 ± 0.43	-7
Safety/shutdown rods 5+6+7+8		IK and PNS	-12.67 ± 0.31	-11.81 ± 0.59	-7

*For cores 4, 9, and 10, the calculated β_{eff} values are 694, 693, and 685 pcm, respectively.